



## Covenant K93792/02

Uitgegeven 2017-12-01

Vervangt K93792/01

Pagina 1 of 5

### Leadax

#### VERKLARING VAN KIWA

With this Covenant, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Leadax B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa Covenant manual K15013 dated 01-01-2016.

Luc Leroy  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# COVENANT

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
Tel. 088 998 44 00  
Fax 088 998 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Leverancier**  
Leadax B.V.  
Vlijtweg 4  
8191 JP WAPENVELD  
Tel. +31 (0)85-0653746  
[info@leadax.com](mailto:info@leadax.com)  
[www.leadax.com](http://www.leadax.com)

# Leadax

---

## 1 Scope of the Covenant

### 1.1 Definition of the product

Lead Free Flashing, made of recycled Polyvinylbutyral (PVB)

Specification nominal value:

Length: 6,0 m  
 Width: 15 - 100 cm  
 Thickness: 3,0 mm  
 Delivered: on roll

#### Intended use of Leadax

- Leadax can be used as a water barrier in (cavity) walls and under casings;
- At the intersection between chimney bases and roof tiles;
- At chimney flashings to provide a water barrier;
- Leadax can be applied to the base of dormers and skylights as a waterproofing layer and at the joint between dormer side walls and tiled roofs;
- As a watertight connection between an outside wall and an extension. Use Leadax masonry clips to attach Leadax to masonry joints;
- Leadax can be used as valley gutters and waterproofing on the ridges of (tiled) roofs.

### 1.2 Assumed working life of the product

The provisions and the verification and assessment methods included or referred to in this Kiwa Covenant have been written based upon the assumed working life of the waterproofing system for the intended use of at least the life expectancy of waterproofing system of 20<sup>1)</sup> years. These provisions are based upon the current state of the art and the available knowledge and experience.

\*) Remark: The expected life time is 30 years, confirmation tests under extreme conditions are running.

"Assumed working life" means that, when an assessment following the Kiwa Covenant provisions is made, and when this working life has elapsed, the real working life may be, in normal use conditions, considerably longer without major degradation affecting the requirements. The indications given as to the working life of the construction product can not be interpreted as a guarantee given by the product manufacturer or his representative or Kiwa Nederland B.V. issuing the Kiwa Covenant, but are regarded only as a means for choosing the appropriate products in relation to the expected economically reasonable working life of the works.

## 2 Fitness for use

### 2.1 Meaning of 'fitness for use'

'Fitness for (the intended) use' of the flashing system means that the products have such characteristics that Leadax, when properly designed and built, satisfies the requirements of this Kiwa Covenant and is fit for its intended use and in this connection satisfies the requirements of this Kiwa Covenant, when properly installed.

### 2.2 Assessment of fitness for use

The relevant characteristics of the waterproofing system for its fitness for use (requirements) and the required verification methods to be employed are given in chapter 3, as well as the actual performed assessment of fitness for use and proven conformance to the relevant characteristics of the waterproofing system and its components.

## 3 Relevant characteristics of the product, the required verification and the assessments of fitness for use

### 3.1 Dimensions

Characteristic	Verification Method	Assessment of the characteristic
Length	EN 1848-2	6,0 m
Width	EN 1848-2	15 – 100 cm
Thickness	EN 1849-2	3,0 mm
Mass / m <sup>2</sup>	EN 1849-2	3,85 kg/m <sup>2</sup>
Visual defects	EN 1850-2	No visible defects
Dimensional stability	EN 1107-2	0,0 %

## Leadax

---

3.2	<b>Reaction to fire</b>		
	<b>Characteristic</b>	<b>Verification Method</b>	<b>Assessment of the characteristic</b>
	Reaction to Fire	EN 13501-1+A1:2009	Class E
3.3	<b>Functional properties</b>		
	<b>Characteristic</b>	<b>Verification Method</b>	<b>Assessment of the characteristic</b>
	Water tightness	EN 1928 - B	500 kPa
	Water tightness of joints (Hot air)	EN 1928 - B	10 kPa
	Water absorption	M.O.A.T 66	1,06 %
	Water tightness (After 2400 hrs UVB test)	EN 1928 – B	500 kPa
	Water Vapour Transmission	EN 1931	Density moisture flow rate (g): 5,26.10-8 kg.m-2.s-1 Moisture resistance factor ( $\mu$ ): 2360
	Water Vapour Transmission after thermal ageing	EN 1296 + EN 1931	Density moisture flow rate (g): 5,20.10-8 kg.m-2.s-1 Moisture resistance factor ( $\mu$ ): 2370

### 3.4 Mechanical properties

<b>Characteristic</b>	<b>Verification Method</b>	<b>Assessment of the characteristic</b>
Tensile properties:		
Maximum tensile force length direction	EN 12311-2	500 N/50 mm
Maximum tensile force width direction	EN 12311-2	1200 N/50 mm
Elongation at break length direction	EN 12311-2	80 %
Elongation at break inwidth direction	EN 12311-2	15 %
Tear resistance length direction	EN 12310-1	400 N
Tear resistance width direction	EN 12310-1	400 N
Static loading (method B)	EN 12730	20 kg
Impact resistance (method B)	EN 12691	2000 mm
Hail resistance (hard support)	EN 13583	44 m s <sup>-1</sup>
Resistance to peel (concrete)	M.O.A.T 66	162 N/50 mm
Resistance to peel (concrete) after thermal ageing at 80 °C, 12 weeks	M.O.A.T 66	143 N/50 mm
Low temperature foldability	EN 495-5	-70 °C
Low temperature foldability after thermal ageing at 80 °C, 12 weeks	EN 495-5	-70 °C

### 3.5 Raw materials

Raw materials are inspected upon arrival according to procedures laid down in ISO 9001:2015

### 3.6 Joint strength (Leadax Sealant)

<b>Characteristic</b>	<b>Verification Method</b>	<b>Assessment of the characteristic</b>
Peel resistance:		
Length direction	EN 12316-2	250 N/50mm
Width direction	EN 12316-2	250 N/50mm
Shear resistance:		
Length direction	EN 12317-2	500 N/50mm
Width direction	EN 12317-2	1200 N/50mm

## Leadax

---

### 3.7 Joint strength (Hot air)

Characteristic	Verification Method	Assessment of the characteristic
Peel resistance:		
Length direction	EN 12316-2	300 N/50mm
Width direction	EN 12316-2	400 N/50mm
Shear resistance:		
Length direction	EN 12317-2	500 N/50mm
Width direction	EN 12317-2	1200 N/50mm

### 3.8 Chemical resistance

Characteristic	Verification Method	Assessment of the characteristic
Chemical resistance to lime milk (Ca(OH) <sub>2</sub> )	EN 1847	Pass

### 3.9 Compatibility

Characteristic	Verification Method	Assessment of the characteristic
Compatibility with bitumen	BRL 1511-1	Pass
Compatibility with PVC	BRL 1511-1	Pass

## 4 Initial inspection and continuous surveillance by Kiwa

### 4.1 Initial inspection

During an initial inspection the IQC-scheme is audited, testing is witnessed and samples are taken for verification. Continuous surveillance will be performed two times a year, during which the process, the IQC-scheme is inspected.

### 4.2 Continuous surveillance

Test frequency

Characteristic	Method	Test frequency
Length	EN 1848-2	once per batch
Width	EN 1848-2	once per batch
Thickness	EN 1849-2	once per batch
Mass / m <sup>2</sup>	EN 1849-2	once per batch
Visual defects	EN 1850-2	once per batch
Chemical resistance (Lime milk)	EN 1847	once per 5 <sup>th</sup> years
Low temperature foldability	EN 495-5	once per 5 years
Impact resistance	EN 12691	once per 5 years
Tensile strength	EN 12311-2	once per month
Elongation at break	EN 12311-2	once per month
Static loading	EN 12730	once per 5 years
Hail resistance	EN 13583	once per 5 <sup>th</sup> years
Reaction to fire	EN 13501-1:2007+A1:2009	once per 5 <sup>th</sup> years
Water tightness	EN 1928	once per 5 years

## Leadax

---

Peel resistance of joints	EN 12316-2	once per 5 <sup>*)</sup> years
Shear resistance of joints	EN 12317-2	once per 5 <sup>*)</sup> years
Peel resistance (concrete)	M.O.A.T 66	once per 5 <sup>*)</sup> years
Peel resistance (concrete) after thermal ageing	M.O.A.T 66	once per 5 <sup>*)</sup> years
Tear resistance	EN 12310-1	once per month

<sup>\*)</sup> In case of unchanged materials and or unchanged production process the frequency may be expanded to 10 years.

### 5 Conditions under which the fitness for the intended use is assessed

#### 5.1 Manufacture of the product

Leadax is produced from a combination of materials according to written specifications as documented in the formulation. The formulation is part of the IQC-scheme and of the audits performed by Kiwa.

The production facility is situated in Wapenveld, The Netherlands.

The product is produced in rolls:

- Nominal thickness 3 mm;
- Nominal length 6 m;
- Nominal width 15 – 100 cm;
- Each roll shall carry a batchnr.;
- Each roll shall carry the Kiwa word mark: Kiwa, the certificate number or the applicable logo.

#### 5.2 General conditions for product application, storage and transport

For current application instructions refer to the packaging.

#### 5.3 Recommendations for customers

Check at the time of deliver whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

Leadax BV

And, if necessary,

Kiwa Nederland B.V.

Consult the suppliers processing guidelines for the proper storage and transport methods.